



Unit 30 | Fern Close | Pen-Y-Fan Ind Est | Oakdale | Gwent | NP11 3EH | UK
Tel: +44 (0) 1495 236260 wales@nsf.org | www.nsf.org

TEST REPORT

Customer: C0690662

H.T.C. SrL
Via dei Ponticelli 2
25040 Corte Franca (BS)
Italy

Result	Limited testing was undertaken on this product in accordance with BS 6920-2.1, clause 6.10.1 (ceramic products). This product has satisfied the criteria set out in BS 6920: Part 1: 2014 "Specification" and thus is suitable for use with hot (up to 85°C) and cold water.
Customer Name	H.T.C. SrL
Product	ALOX-C 99,0% Ceramic
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00433194
Work Order Number	W0752955

Thank you for having your product tested by NSF Wales Ltd.

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

Report Date 16-AUG-2022

Report Authorisation

Michael Bustin - Materials Testing Manager



0626



Result Summary Section

Test	Result
Extraction of Metals BS 6920: Part 1: 2014, Clause 8 - 85°C	Pass