



Unit 30 | Fern Close | Pen-Y-Fan Ind Est | Oakdale | Gwent | NP11 3EH | UK  
Tel: +44 (0) 1495 236260 wales@nsf.org | www.nsf.org

# TEST REPORT

**Customer: C0690662**

H.T.C. SrL  
Via dei Ponticelli 2  
25040 Corte Franca (BS)  
Italy

---

<b>Result</b>	Limited testing was undertaken on this product in accordance with BS 6920-2.1, clause 6.10.1 (ceramic products). This product has satisfied the criteria set out in BS 6920: Part 1: 2014 "Specification" and thus is suitable for use with hot (up to 85°C) and cold water.
Customer Name	H.T.C. SrL
Product	ALOX-G 95,0% Brown Ceramic
Test Undertaken	BS 6920: 2014 - Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water
Job Number	J-00433196
Work Order Number	W0752955

---

**Thank you for having your product tested by NSF Wales Ltd.**

Please contact your Account Manager if you have any questions or concerns pertaining to this report.

**Report Date** 16-AUG-2022

**Report Authorisation**

Michael Bustin - Materials Testing Manager



0626



---

## Result Summary Section

<b>Test</b>	<b>Result</b>
Extraction of Metals BS 6920: Part 1: 2014, Clause 8 - 85°C	Pass